



Town of Dagsboro

P.O. Box 420

Dagsboro, DE 19939

PWSID: DE00A0799

Report Created: May 2023



2022

WATER

QUALITY

REPORT

Artesian Water Company, Dagsboro's water operator, is pleased to provide this Water Quality Report for the year 2022. Please note that substances such as iron, chloride, and sodium are commonly found in drinking water. They occur naturally at trace levels, and the United States Environmental Protection Agency (EPA) has deemed that these substances pose no health hazard from consumption in drinking water. This report indicates the concentrations of these and many other substances obtained during analyses performed from January 1, 2022 – December 31, 2022 unless otherwise specified. If you have any questions about this report or the quality of your tap water, please call Cynthia Brought at (302) 732-3777.

A Safe Water Source

The water serving your home was from the Millsboro Water Department via an interconnection until January 10, 2022. Although we purchased the water, all water testing was done within Dagsboro's system. Millsboro has three (3) wells, one located in the Manokin aquifer and the other two located in the Columbia aquifer. The Manokin aquifer is confined and protected from the influence of past farming activities and salt water intrusion. The Columbia aquifer is unconfined and is potentially subject to contamination from nutrients and pesticides. Since January 10, 2022 the water serving your home comes from Artesian's Southern Sussex Regional water system via an interconnection. The Artesian Southern Sussex Regional water system is supplied with water from seven (7) wells located in Sussex County. These wells are located in the Manokin and Pocomoke formations. These wells are located in confined aquifers that provide additional protection from surface-borne contaminants. The Artesian Southern Sussex Regional water systems water quality report can be found at <https://www.artesianwater.com/wp-content/uploads/wqsb2022.pdf>

Source Water Assessment Plan

The Division of Public Health, in conjunction with the Department of Natural Resources and Environmental Control, has conducted source water assessments for nearly all community water systems in the state of Delaware. The Source Water Assessment report for Dagsboro can be obtained by contacting Cynthia Brought at (302) 732-3777 or by visiting the Source Water Assessment Program website at: <http://delawaresourcewater.org/assessments/>.

Expected Substances in Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive materials, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Definition of Terms

The following tables contain these terms and abbreviations.

90th Percentile

The ninth highest (out of a total of 10) lead and copper readings. This value is used to determine compliance with the Lead & Copper Rule.

Action Level

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a public-water system must follow.

Maximum Contaminant Level (MCL)

The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG)

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Non-detect (nd)

Laboratory analyses using the state-approved methods indicate that the contaminant is not present.

Not regulated (n/r)

No MCL or SMCL is identified because the substance is unregulated. (It is unregulated because the State of Delaware has deemed that the substance poses no risk to health in any concentration in drinking water.)

Parts per billion (ppb)

One part of the named substance in a billion parts of the drinking water. Equivalent relationships are one minute in 2,000 years or one penny in \$10,000,000.

Parts per million (ppm)

One part of the named substance in a million parts of the drinking water. Equivalent relationships are one minute in 2 years or one penny in \$10,000. (1 ppm equals 1,000 ppb.)

If You Have a Special Health Concern

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead In Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the EPA Safe Drinking Water Hotline at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>.

Public Meeting Information

For the opportunity to ask more questions or participate in decisions that may affect your drinking water quality, a public meeting is held the third Monday of each month, at 6:00 p.m. at the Bethel Center at 107 Clayton Street.

Substances Detected

Substance/Parameter	Violation Yes / No	Unit of Measure	Highest Level Allowed (MCL)	Ideal Goal (MCLG)	Highest Level Detected	Annual Range	Major Sources
Inorganic Contaminants							
Fluoride (Field)	N	ppm	2	2	1.02	0.36 – 1.02	Erosion of natural deposits. Runoff from fertilizer use.
Disinfection/Disinfection By-products							
Chlorine, free and total (Field)	N	ppm	4	4	2.18	0.13 – 2.18	Disinfectant used in drinking water industry.
Delaware Secondary Standards							Average Levels
Iron (Field)	N	ppm	n/r		0.19	0.01 – 0.19	0.06
pH (Field)	N	0-14 scale	n/r		7.23	6.71 – 7.23	6.93
Alkalinity, total (2021 data)	N	ppm	n/r		44.2	44.2 – 44.2	44.2
Chloride (2021 data)	N	ppm	n/r		13.8	13.8 – 13.8	13.8
Sodium (2021 data)	N	ppm	n/r		19.4	19.4 – 19.4	19.4
Sulfate (2021 data)	N	ppm	n/r		2.6	2.6 – 2.6	2.6
Lead & Copper	Violation Yes / No	Unit of Measure	Action Level	Ideal Goal (MCLG)	90th Percentile		Major Sources
90th Percentile Lead	N	ppb	15	0	2		Corrosion of household plumbing systems, erosion of natural deposits.
Number of Sites Exceeding Lead Action Level				0			
90th Percentile Copper	N	ppm	1.3	1.3	0.189		Corrosion of household plumbing systems, erosion of natural deposits.
Number of Sites Exceeding Copper Action Level				0			

The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.